



American Test Lab, Inc.
1656 Calvert Road, Brevard, N. C. 28712
Phone (828) 884-3700 Fax (828) 884-3710
Web www.atlnc.com E-Mail atli@citcom.net

To Whom It May Concern:

record-usa Series 5900 manual ICU sliding doors have successfully passed all testing required for compliance with criteria defined in UL 1784 Sections 7.1, 7.2 / NFPA 105-07. By doing so, the Series 5900 manual ICU sliding door product has achieved air and smoke infiltration ratings. Testing was conducted at ATL in Brevard, NC on a single slide Series 5900 Trackless ICU product.

Air leakage levels of less than 1 cu. ft. per min. per square ft. of opening were achieved, well below the 3 cu. ft. per min. per square ft. of opening required by the standards.

A copy of the test report is available upon request to sales@record-usa.com.

Sincerely

Keith Owen
Lab Manager / ATLNC

A handwritten signature in blue ink that reads "Keith Owen".

12/22/08